



## **SERVICE MAINTENANCE WORK**

Aerated Wastewater Treatment Systems must be serviced once every three months as per Council and NSW Health department approval conditions.

We provide a twelve-month Service Maintenance Contract consisting of four services completed quarterly.

During the scheduled services, Econocycle will perform (where appropriate) the following:

- Test Alarm
- Replenish Chlorine tablets
- Test water quality
- Inspect Air Blower and clean filter
- Inspect and test operation of submersible pump and high-water float
- Inspect irrigation system
- Adjust air supply and sludge return controls
- Monitor sludge levels
- Monitor and record complete operation of plant
- Cleaning of filters when required
- Provide service report to owner and Council

**Your system is fitted with an alarm to alert you the system requires attention  
press the mute button and contact our office**

### **SERVICE MAINTENANCE WORK NOT INCLUDED**

- Requested call-out between quarterly services – breakdown or flooded units (warranty excluded)
- Additional service charges apply for parts plus labour

Should you have any questions or concerns, please do not hesitate to contact us.

**Eco-Septic Pty Limited t/a Econocycle**  
**65 Warradale Road**  
**Warragamba NSW 2752**  
**Office: 4774 1316**  
**Email: [service@econocycle.com.au](mailto:service@econocycle.com.au)**